

Integrated Security Automation Systems Upgrades

For Marathon County Jail and Juvenile Facility

Addendum #1 November 11, 2025

Proposal Due Date Extension: The due date for proposals has been extended to **Tuesday December 9, 2025, at 2:00 P.M.**

Questions/Clarifications:

1. Did Accurate provide a schedule for all the doors and intercoms?
Answer: There are no schedules being provided for the existing devices. It is up to the proposer to ensure proper counts and equipment rooms that devices are routed to. Photos and counts should have been taken during the mandatory walk-through.
2. Did Accurate Controls provide a BOM/Enclosure requirements?
Answer: Any new enclosures that the bidder will be providing needs to follow section 28 05 10.
3. Did Accurate provide locations on the prints of where new 120v outlets need to be placed and whether they need to be generator outlets or standard?
Answer: All existing locations can reuse the existing 120VAC circuits. All new 120VAC circuits will be determined by any new equipment cabinet locations being provided by the proposer. All new 120VAC circuits will be from the emergency power panels.
4. In the actual proposal do we need to provide all new PLC cabinets or are we reusing them?
Answer: The existing enclosures can be reused. The proposer will need to determine where they need to replace existing enclosures per the equipment they are providing. If any existing enclosures are being reused, all equipment and backplanes will be removed and replaced.
5. Did Accurate provide counts on all devices (120v relays, 220v relays, etc.)?
Answer: There are no schedules being provided for the existing devices. It is up to the proposer to ensure proper counts and equipment rooms that devices are routed to. Photos and counts should have been taken during the mandatory walk-through.
6. Are there a number of auxiliary controls (outlets, water, lighting, etc.)?
Answer: There are no schedules being provided for the existing devices. It is up to the proposer to ensure proper counts and equipment rooms that devices are routed to. Photos and counts should have been taken during the mandatory walk-through.
7. Our legal team is wondering if language can be added to the contract if awarded?

The awarded proposer will be able to negotiate some language into the contract, but Marathon County Corporation Council will have to approve any changes.

***Acknowledge this receipt of this addendum in your proposal.**